

Prüfbericht - Nr.: 15054162 001					
<i>Test Report No.:</i>					
Auftraggeber:		ANJI HUACHENG ELECTRICS CO., LTD.			
<i>Client:</i>		<i>XIAOSHU INDUSTRIAL ZONE, MEIXI, ANJI, HUZHO, ZHEJIANG, P.R.CHINA.</i>			
Gegenstand der Prüfung: Floor Standing Cabinet					
<i>Test item:</i>					
Bezeichnung:		PR8/PR9			
<i>Identification:</i>					
Wareneingangs-Nr.:		154010569	Eingangsdatum:		02.08.2012
<i>Receipt No.:</i>			<i>Date of receipt:</i>		
Zustand des Prüfgegenstandes bei Anlieferung:			No damage		
<i>Condition of test item at delivery:</i>					
Prüfart:		TÜV Rheinland (Shanghai) Co., Ltd.			
<i>Testing location:</i>		<i>B1-13F No. 177, Lane 777 West Guangzhong Road, Zhabei District Shanghai, P.R. China.</i>			
Prüfgrundlage:		EN 62208: 2003 Clause 9.7			
<i>Test specification:</i>					
Prüfresultat:		Der Prüfgegenstand entspricht oben genannter Prüfgrundlage(n).			
<i>Test Result:</i>		<i>The test item passed the test specification(s).</i>			
Prüflaboratorium:		TÜV Rheinland (Shanghai) Co., Ltd.			
<i>Testing Laboratory:</i>		<i>B1-13F No. 177, Lane 777 West Guangzhong Road, Zhabei District Shanghai, P.R. China.</i>			
geprüft/ tested by:			kontrolliert/ reviewed by:		
22.08.2012  Leeham Zhuang / PE			23.08.2012 Zhang jie/ Reviewer 		
Datum	Name/Stellung	Unterschrift	Datum	Name/Stellung	Unterschrift
<i>Date</i>	<i>Name/Position</i>	<i>Signature</i>	<i>Date</i>	<i>Name/Position</i>	<i>Signature</i>
Sonstiges/ Other Aspects:					
Attachment 1: Measurement equipment list (1 page).					
Abkürzungen: P(ass) = entspricht Prüfgrundlage F(ail) = entspricht nicht Prüfgrundlage N/A = nicht anwendbar N/T = nicht getestet			Abbreviations: P(ass) = passed F(ail) = failed N/A = not applicable N/T = not tested		
Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens. <i>This test report relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any safety mark on this or similar products.</i>					

TEST REPORT
IEC / EN 62208
Empty enclosures for low voltage switchgear and controlgear assemblies –
General requirements

Report Reference No.....	15054162 001
Tested by (name + signature).....	See cover page
Witnessed by (name + signature).....	N/A
Supervised by (name + signature)....	See cover page
Approved by (name + signature).....	See cover page
Date of issue	See cover page
CB Testing Laboratory	TÜV Rheinland (Shanghai) Co., Ltd.
Address.....	B1-13F No. 177, Lane 777 West Guangzhong Road, Zhabei District Shanghai, P.R. China.
Testing location/ procedure.....	TÜV Rheinland (Shanghai) Co., Ltd.
Testing location/ address	B1-13F No. 177, Lane 777 West Guangzhong Road, Zhabei District Shanghai, P.R. China.
Applicant's name	ANJI HUACHENG ELECTRICS CO., LTD.
Address	XIAOSHU INDUSTRIAL ZONE, MEIXI, ANJI, HUZHOU, ZHEJIANG, P.R.CHINA.
Test specification:	
Standard	IEC 62208:2002 (Edition 1.0)/ EN 62208:2003
Test procedure.....	CB / CCA
Non-standard test method.....	N/A
Test Report Form No.	IECEN62208A
TRF Originator	OVE
Master TRF	Dated 2004-07
Copyright © 2004 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test item description.....	Floor Standing Cabinet
Trade Mark.....	N/A
Manufacturer.....	ANJI HUACHENG ELECTRICS CO., LTD.
Model/Type reference	PR8/PR9
Ratings.....	IP55